



**MUNICIPAL SERVICES DEPARTMENT**  
**ROADS PROGRAM**  
**156 S. BROADWAY, SUITE 150**  
**TURLOCK, CA 95380**

PHONE: (209) 668-5520  
FAX: (209) 668-5563  
TDD: (800) 735-2929

---

Addendum No. 1

February 11, 2026

**City Project No. 23-068 Package 3  
Roads Program Capital Improvement Project**

Plan holders:

This addendum includes revisions to Plans and Specifications and provides clarifications and answers to questions submitted to the City.

**Revisions to Plans and Specifications**

The following additions, deletions or modifications shall become part of the Contract Documents:

Strikethrough text (~~text~~) indicates deletions.

Bold Italicized text (***text***) indicates additions.

---

**Item No. 1:**

Q1: Can the city please provide a typical cross section for the following streets?

- Marshall ST
- Sycamore ST
- Merritt ST
- Villa CT
- Elena CR
- Andrews CT
- Fairvale CT
- Bell ST

A1: Please see detail 2 on sheet D5 for a typical cross section that covers all the streets listed.

---

**Item No. 2:**

Q2: Please confirm Polyvinyl-Chloride (PVC) pipe SDR-26 will not be acceptable for use under bid item 38 (18" Storm Drain Pipe).

A2: Per Engineering Plans and Specifications, all Storm drain pipe shall be reinforced concrete pipe.

---

**Item No. 3:**

The Engineer's Estimate for this project has been updated and is posted at <https://ci.turlock.ca.us/capitalprojects/projectsouttobid/> .

---

**End of Addendum No. 1**