



**MUNICIPAL SERVICES DEPARTMENT**  
**ROADS PROGRAM**  
**156 S. BROADWAY, SUITE 150**  
**TURLOCK, CA 95380**

PHONE: (209) 668-5520  
FAX: (209) 668-5563  
TDD: (800) 735-2929

---

Addendum No. 2

February 12, 2026

**City Project No. 23-068 Package 3  
Roads Program Capital Improvement Project**

Plan holders:

This addendum includes revisions to Plans and Specifications and provides clarifications and answers to questions submitted to the City.

**Revisions to Plans and Specifications**

The following additions, deletions or modifications shall become part of the Contract Documents:

Strikethrough text (~~text~~) indicates deletions.

Bold Italicized text (***text***) indicates additions.

---

**Item No. 1:**

This answer replaces the response to Question No. 2 under Item No. 2 in Addendum 1:

For storm drain piping requirements, refer to Section 17-3 of the City of Turlock Standard Specifications and Drawings 2016. Storm Drain Pipe may be reinforced concrete pipe, cast-in-place concrete pipe, or PVC pipe. If storm drain pipe is PVC, it shall be SDR-26 per Project Specifications.

---

**End of Addendum No. 2**