



DEVELOPMENT SERVICES
ENGINEERING DIVISION
156 S. BROADWAY, SUITE 150
TURLOCK, CA 95380

PHONE: (209) 668-5520
FAX: (209) 668-5563
TDD: (800) 735-2929
engineering@turlock.ca.us

Date: 11/24/20

City Project No.: 20-011

Addendum No.: 2

Plan holders:

The following changes shall be made to the contract documents:

Item #1:

Some older versions of Adobe Reader are not displaying the attached Trench Detail table on the plan's cover sheet. Existing trenches are rectangular in shape unless otherwise specified on Sheet 2. Per City Standards and Specifications: any lane affected by the trench repairs must be replaced for the full width of the lane, regardless of how far the repairs extend into the lane. The Grinding Area T-3 quantities in the Trench Detail table includes full lane width repairs.

Item #2:

Replace Drawing T-5 on Sheet 3 with the attached revised Drawing T-5

If you have any questions, please call me at (209) 668-5428 or email at ahutchings@turlock.ca.us.

Sincerely,


Adam Hutchings, PE
Associate Civil Engineer

Attachments:

1. Trench Detail Table
2. Revised Drawing T-5

Trench Detail Table from Cover Sheet of Plans

ID #	TRENCH LOCATION	UTILITY	DIA (IN)	LENGTH (FT)	WIDTH (FT)	TRENCH AREA T-1, T-2 (SQ FT)	GRINDING AREA T-3 (SQ FT)
1	1662 E. MARSHALL ST	WATER	8	SEE SHEET 2		660.0	1,620.0
2	1240 VALLEY VIEW DR	WATER	6	19.00	2.50	47.5	190.0
3	2660 E MARSHALL ST	WATER	6	6.00	4.50	27.0	190.0
4	560 S MINARET AVE	SEWER	6	25.00	7.50	187.5	400.0
5	EDWARD DR & EL CAPITAN DR	WATER	6	7.50	6.00	45.0	175.0
6	550 BELL ST	SEWER	8	6.00	5.00	30.0	150.0
7	400 SOUTH AVE	WATER	18	7.00	9.50	66.5	175.0
8	W OLIVE AVE AND GRANT AVE	WATER	4	12.00	9.00	108.0	150.0
9	BELL ST AND EAST AVE	WATER	10	25.00	2.50	162.5	600.0
10	1245 LAMBERT WAY	SEWER	6	SEE SHEET 2		106.0	350.0
11	1905 ROTH CT	SEWER	6	24.00	4.00	96.0	240.0
12	837 9TH ST	SEWER	8	SEE SHEET 2		45.5	100.0
13	1302 N DENAIR AVE	WATER	6			106.0	200.0
14	460 VASSAR AVE	SEWER	6			80.0	400.0
15	120 W F ST	WATER	10			143.0	700.0
16	1851 E MARSHALL ST	SEWER	18			130.0	490.0
17	1645 LOGAN LN	WATER	8			21.0	175.0
18	145 WEST AVE N	SEWER	10	24.00	2.50	60.0	400.0



ADDITIONAL NOTES:

GRINDING AND FINAL PAVING WIDTH SHALL BE TO THE EXTENT OF AFFECTED LANE LINES
 IF TRENCHES CROSS LANE LINES, GRINDING AND FINAL PAVING WIDTH SHALL BE TO THE EXTENT OF ALL AFFECTED LANE LINES FOR ENTIRE LENGTH OF TRENCH.

NOTES:

1. GRINDING AND PAVING WIDTH SHALL BE 10' MIN.
2. ALL CUTS SHALL BE SQUARE AND PERPENDICULAR TO THE TRAVEL LANE

PERPENDICULAR TRENCH PATCH LIMITS



DRAWN BY: JSH

CHECK BY: NBB

SCALE: NONE

CITY OF TURLOCK

APPROVED BY:

Nathan B. Bray
 INTERIM CITY ENGINEER - NATHAN B. BRAY - RCE 76642

DRAWING NO.

T-5

COUNCIL APPROVAL

FEB, 2019